



SECTIONAL VIEW - GEARLESS TYPE 4




2 MOUNTING POSITIONS
CENTER OR SIDE




FINAL RAIL BRACKET RB3	BELOW THE MOTOR CONSULT YOUR REPRESENTATIVE FOR EXACT LOCATION
INTERMEDIATE RAIL BRACKET RB2	32" (813mm) INTERVALS AFTER 2nd BOTTOM BRACKET
BOTTOM RAIL BRACKET RB1	44" (1118mm) & 71" (1804mm) ABOVE PIT FLOOR

MOUNTING BRACKET
4 WALL ANCHOR POINTS MIN. PER BRACKET
2 PER SIDE OF RAIL BRACKET CENTER LINE
PULL OUT FORCE PER FASTENER 69 kg (152 LBS)

HALL BUTTON NEEDED AT ALL FLOORS
DOOR SWING




PLAN VIEW - GEARLESS TYPE 4




CLEAR INSIDE CAB WIDTH	CLEAR INSIDE CAB LENGTH	A FINISHED RUNWAY WIDTH		B FINISHED RUNWAY LENGTH		C RAIL CENTER LINE		D DOOR CENTER LINE		E DOOR CENTER LINE			
		mm	Inches	mm	Inches	mm	Inches	mm	Inches	mm	Inches		
914	36	1219	48	1403	55 1/4	1441	56 3/4	787	31	781	30 3/4	876	34 1/2
914	36	1372	54	1403	55 1/4	1556	61 1/4	838	33	781	30 3/4	1029	40 1/2
914	36	1524	60	1403	55 1/4	1708	67 1/4	914	36	781	30 3/4	1181	46 1/2
1016	40	1372	54	1505	59 1/4	1556	61 1/4	838	33	883	34 3/4	1029	40 1/2

RAIL FORCES



* R1	* R2
1382 kg (3047 lbs)	882 kg (1944 lbs)
RAIL WEIGHT: 643 kg / 7' (1418 lbs / 21')	RAIL WEIGHT: 643 kg / 7' (1418 lbs / 21')
PIT FLOOR TO SUPPORT LOAD (EXCLUDES IMPACT): 2909 kg (6440 lbs)	

ENTRANCE SIDE LEGEND



RESIDENTIAL ELEVATOR
GEARLESS TYPE 4

CUSTOMER: _____ DATE: _____
 PROJECT: _____
 LOCATION: _____
 THE INFORMATION REQUESTED HEREON IS THE EXCLUSIVE PROPERTY OF Savaria
 AND MAY NOT BE USED BY OTHERS WITHOUT PRIOR WRITTEN CONSENT
 1/1